

MINE SAFETY APPLIANCES CO -- 463464,CALIBRATION GAS,2.5% METHANE IN AIR --
6665-00-401-8500

===== Product Identification =====

Product ID:463464,CALIBRATION GAS,2.5% METHANE IN AIR

MSDS Date:03/04/1993

FSC:6665

NIIN:00-401-8500

Kit Part:Y

MSDS Number: BRQNW

=== Responsible Party ===

Company Name:MINE SAFETY APPLIANCES CO

Box:426

City:PITTSBURGH

State:PA

ZIP:15230

Country:US

Info Phone Num:412-967-3000

Emergency Phone Num:412-967-3000

CAGE:40912

=== Contractor Identification ===

Company Name:MINE SAFETY APPLIANCE (REPLACED BY CAGE 55799)

Address:201 N BRADDOCK AVENUE

Box:426

City:PITTSBURGH

State:PA

ZIP:15230

Country:US

Phone:412-967-3000

CAGE:40912

Company Name:MINE SAFETY APPLIANCES CO DBA MSA

Address:3880 MEADOWBROOK RD

Box:City:MURRYSVILLE

State:PA

ZIP:15668-1753

Country:US

Phone:724-733-9272

CAGE:55799

===== Composition/Information on Ingredients =====

Ingred Nam

e:METHANE
CAS:74-82-8
RTECS #:PA1490000
Fraction by Wt: 2.5%
Other REC Limits:NONE RECOMMENDED
ACGIH TLV:ASPHYXIAN; 9293

Ingred Name:AIR, REFRIGERATED LIQUID; AIR COMPRESSED (UN1002, DOT); AIR
REFRIGERATED LIQUID (CRYOGENIC LIQUID) (UN1003) (DOT)
RTECS #:AX5271000
Fraction by Wt: BALANCE
Other REC Limits:NONE RECOMMENDED

=====
===== Hazards Identification =====

LD50 LC50 Mixture:NOT KNOWN
Routes of Entry: Inhalation:YES Skin:NO Ingestion:NO
Reports of Carcin
ogenicity:NTP:NO IARC:NO OSHA:NO
Health Hazards Acute and Chronic:ACUTE- METHANE IS A SIMPLE ASPHYXIAN.
NO SIGNS OR SYMPTOMS OF EXPOSURE ARE KNOWN FOR 2.5% METHANE IN AIR.
TARGET ORGANS IS LUNG.
Effects of Overexposure:NOT KNOWN
Medical Cond Aggravated by Exposure:NOT KNOWN

=====
===== First Aid Measures =====

First Aid:FOR INHALATION OVEREXPOSURE REMOVE TO FRESH AIR, PROVIDE
CPR/OXYGEN IF NEEDED. GET MEDICAL HELP.

=====
===== Fire Fi
ghting Measures =====

Extinguishing Media:USE WATER FOG, CARBON DIOXIDE, FOAM, OR DRY
CHEMICAL FOR SURROUNDING FIRE. THIS CALIBRATION GAS MIXTURE IS NOT
FLAMMABL.
Fire Fighting Procedures:EVACUATE ALL PERSONNEL FROM DANGER AREA.
IMMEDIATELY DELUGE CONTAINERS WITH WATER SPRAY FROM MAXIMUM
DISTANCE UNTIL COOL, THEN MOVE CONTAINERS AWAY IF NO RISK.
Unusual Fire/Explosion Hazard:GAS UNDER PRESSURE, 115 PSIG AT 70 F.
CONTAINERS MAY EXPLODE IN THE HEAT OF FIRE.

=

===== Accidental Release Measures =====

Spill Release Procedures: VENTILATE AREA.
Neutralizing Agent: NONE

===== Handling and Storage =====

Handling and Storage Precautions: STORE IN A COOL, DRY, WELL-VENTILATED AREA. DO NOT EXCEED 120 F.
Other Precautions: AVOID BREATHING GAS. USE IN WELL VENTILATED AREAS. FOLLOW THE CALIBRATION PROCEDURE DETAILED IN THE MSA INSTRUCTION MANUAL PROVIDED WITH THE INSTRUMENT UNDER CALIBRATION.

===== Exposure Controls/Personal Protection =====

Respiratory Protection: DUE TO THE LIMITED AMOUNT OF GAS IN THE CYLINDER AND THE LOW RELEASE RATE EMPLOYED IN INSTRUMENT CALIBRATION, RESPIRATORY PROTECTION IS NOT INDICATED UNDER CONDITIONS OF INTENDED USE.
Ventilation: MECHANICAL VENTILATION IS SUITABLE.
Protective Gloves: NO
Eye Protection: SAFETY GLASSES OR GOGGLES RECOMMENDED
Other Protective Equipment: SAFETY SHOES OPTIONAL
Work Hygienic Practices: WASH HANDS THOROUGHLY BEFORE EATING OR DRINKING AND AFTER HANDLING.
Supplemental Safety and Health

===== Physical/Chemical Properties =====

HCC: G3
Vapor Pres: GAS
Vapor Density: